



CENTEXBEL TYPE TESTING | CERTIFICATION REPORT N° jw2388_2023

According to reports N° 23.02862.01, 23.02864.01, 23.02864.03 dated on 30/06/2023, 20/06/2023, 30/06/2023, we confirm that the below mentioned items were tested at CENTEXBEL, Notified body \neq 0493, with reference to EN 14041:2004+AC:2006 – Resilient, textile and laminate floor coverings - Essential characteristics.

The item shows

EU fire classification: B_{fl}-s1 (EN 13501-1) Glued on a non-combustible substrate¹ Glued on a combustible substrate²

Compliance with content of pentachlorophenol (EN 14041 annex B)

Formaldehyde class: E1 (EN 16516)

Dynamic coefficient of friction: Dry slip resistance (EN 13893)

Thermal resistance: 0.0074 m²·K/W (ISO 8302)

Provided that it is properly applied.

The evaluation of these properties is based on evaluation scheme specified in EN 14041:2004+AC:2006 – Resilient, textile and laminate floor coverings - Essential characteristics. These products come under the EU CPR 305/2011 directives for product safety.

Products fall under system 3 of assessment and verification of constancy of performance like declared by the manufacturer.

Product family Company

Dryback

Republic Floor GmbH

Lise-Meitner-Strasse 1

82152 Germany

Certificate No. jw2388_2023 is valid until 19/06/2028 Centexbel | Technologiepark 7 | BE 9052 Gent | Belgium, 26/07/2023

Jo Wynendaele, PhD i.o. Inge De Witte, PhD Certification Manager



¹End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)

²End use substrates of wood and of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)